

FACT SHEET

Secondary vs. Supplemental Disinfection Systems

Brought to you by the PHTA Recreational Water Quality Committee (RWQC)

I. INTRODUCTION

Proper sanitation helps keep pools free of microorganisms that can lead to and cause waterborne illnesses. Traditionally, the primary source of sanitation has been a halogen (chlorine or bromine). We are now finding that halogen-tolerant pathogens, such as *Cryptosporidium*, require the use of an *additional* means to disinfect pools.

This fact sheet will focus on the equipment for Secondary or Supplemental Treatment Systems used in commercial pools as defined by ANSI/APSP/ICC-11 *American National Standard for Water Quality in Public Pools and Spas*.

II. SUMMARY OF CHARACTERISTICS

- **SECONDARY DISINFECTION SYSTEMS:** Disinfection processes or systems installed in addition to the required primary disinfection systems. Secondary disinfection systems are required for increased risk aquatic venues.
- **SUPPLEMENTAL TREATMENT SYSTEMS:** Systems or processes which are not required in an aquatic venue for health and safety reasons but may be used to improve water quality and/or enhance overall system performance.

III. GENERAL DESCRIPTION

- A. **SECONDARY DISINFECTION SYSTEMS** – Equipment designed to achieve a minimum 3-log (99.9%) reduction in the number of infective *Cryptosporidium parvum* oocysts and other pathogenic microorganisms per pass through the secondary disinfection system at the maximum flow rate.

These systems shall be listed and labeled to NSF/ANSI Standard 50 *Equipment for Swimming Pools, Spas, Hot Tubs and Other Recreational Water Facilities* by an American National Standards Institute (ANSI)-accredited certification organization and shall be installed according to the manufacturer's directions. When listed as an NSF-approved system, it is classified as a sanitizer.

PHTA Fact Sheets are for information purposes only. The Fact Sheets are based on the best information available at the time of publication and represent a consensus of the volunteer members of the applicable PHTA committee(s). Appropriate steps should be taken to ensure that the information is current when used.

The Fact Sheets do not constitute any promise, representation or warranty that a product or application referenced will in fact comply with applicable federal, state, or municipal laws, codes, rules and regulations concerning the intended use of such produce ("Laws"), nor any assurance,

representation or guarantee regarding or relating in any manner to the safety of any product or application that is referenced. Not every acceptable procedure is included, and special circumstances may warrant modified or additional procedures.

Fact Sheets are intended for the use of trained professionals in the pool and spa industry, in conjunction with prior training and knowledge. Where appropriate, industry members should seek the advice of knowledgeable persons to ascertain whether a product or application is appropriate or will in fact comply with applicable Laws. The use of information or recommendations in

this Fact Sheet is voluntary, and its applicability and suitability for any particular use is the sole responsibility of the user. Nothing in the Fact Sheets should be interpreted as expressing either approval of, or disapproval of, any product or service.

The PHTA expressly disclaims liability to any and all persons and entities for personal injury, property damage, and any other damage of any kind or nature, (whether or not such damages are direct, indirect, consequential or compensatory) resulting from, or in any way relating to these fact sheets.

PHTA **FACT SHEET**

Increased risk aquatic venues have a higher risk of microbial contamination due to their primary users being children under the age of 5 and/or people more susceptible to infection, such as therapy patients with open wounds. All new construction or substantial alteration of the following increased risk aquatic venues are required to use a secondary disinfection system.

- Wading Pools
- Interactive Water Play Venues
- Other aquatic venues designed primarily for children under the age of 5
- Therapy Pools

Secondary disinfection systems may be installed on other aquatic venues. At present secondary disinfection systems are either Ozone or Ultraviolet (UV) Light systems. These systems require the use of a primary disinfecting halogen, such as chlorine or bromine.

- B. SUPPLEMENTAL TREATMENT SYSTEMS** – Equipment designed to enhance water quality, but not required to achieve the minimum 3-log (99.9%) reductions of secondary disinfection systems.

Secondary treatment systems (such as ozone or UV) can also be considered supplemental systems when they are not required at an increased risk venue.

Metal ion-based systems are often used as supplemental treatment systems.

Supplemental treatment systems require the use of a primary disinfecting halogen, such as chlorine or bromine.

IV. APPLICATION

OZONE SECONDARY DISINFECTION SYSTEM

An oxidation reaction occurs once ozone has been dissolved in water. Once this reaction takes place, organic contaminants are destroyed, and many dissolved metals become insoluble.

Ozone is capable of killing all known microorganisms (including *Cryptosporidium* and *Giardia*), destroying organic contaminants that may create chloramines and break down existing chloramines. This oxidation occurs immediately at the ozone gas injection point and continues in the return lines. A small residual (~0.1 ppm) of dissolved ozone may enter the pool, providing further oxidation.

An ozone-generating system is considered a pesticidal device under the U.S. EPA Federal Insecticide, Fungicide, and Rodenticide Act (FIFRA) and has an EPA Establishment number.

Commercial ozone-generating systems are tested and listed under NSF/ANSI Standard 50. The device must meet the requirements of NSF 50, Disinfection Efficacy in Section 14.20 and must be used with an EPA-registered sanitizer to impart residual concentrations in accordance with federal, state or local regulations.

The use of secondary systems in combination with a primary halogen should be used in accordance with manufacturer's recommendations.

ULTRAVIOLET LIGHT SECONDARY DISINFECTION SYSTEM

UV Light Systems use a process known as “Photolysis” to inactivate microorganisms (including *Cryptosporidium* and *Giardia*). The intensity of the lamp and the flow rate through the unit will produce a “dosage” measured in mJ/cm³. UV light is most effective at a known wavelength of 254 nm. Commercial Ultraviolet Light systems are tested and listed under NSF/ANSI Standard 50. The device must meet the requirements of NSF 50, Disinfection Efficacy, in Section 14.20 and must be used with an EPA-registered sanitizer to impart residual concentrations in accordance with federal, state or local regulations.

WHAT ULTRAVIOLET LIGHT AND OZONE DO AS A SUPPLEMENTAL TREATMENT SYSTEM

Both Ozone and Ultraviolet Light systems can also be used as supplemental treatment systems. These systems enhance both water and indoor air quality. Air quality has become critical in protecting swimmers, pool attendants, spectators or anyone spending time in an indoor pool environment. Both UV Light and Ozone systems have been proven to be effective in destroying chloramines in swimming pools and therefore improve indoor air quality.

Supplemental systems in combination with a primary halogen should be used in accordance with manufacturer’s recommendations.

METAL-BASED SYSTEMS

While metal-based systems have been recognized as EPA-registered sanitizer systems when used with a primary halogen, the metal ionizer component has always served as a supplemental treatment system to the halogen.

V. REFERENCES

1. ANSI/APSP/ICC-11 2019 *American National Standard for Water Quality in Public Pools and Spas*, Pool & Hot Tub Alliance (formerly The Association of Pool & Spa Professionals), 2019
2. NSF/ANSI Standard 50 *Equipment for Swimming Pools, Spas, Hot Tubs and Other Recreational Water Facilities*, 2019
3. Recreational Water Quality Committee “Copper-Silver Ionizers” Fact Sheet, 2012, Pool & Hot Tub Alliance, <https://www.apsp.org/resources/information-bulletins>